

## Performance Data Sheet

# Spirit 300Cp



**C US**

**This system has been tested according to NSF/ANSI 58, 372 and CSA B483.1 for reduction of the substance listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in NSF/ANSI 58. The substance is:  
TDS**

This reverse osmosis system contains replaceable treatment components, critical for the effective reduction of total dissolved solids. It is the user's responsibility to, and the manufacturer strongly recommends that the user, periodically have the product water tested to verify the system is performing properly.

If Spirit 300Cp filters and membrane elements are not used, health related contaminant reduction claims are invalid.

## SPECIFIC CONTAMINANT PERFORMANCE

Contaminants	Influent (avg. mg/L)	Effluent (ave. mg/L)	Ave. % reduction
TDS	740	34.6	95.3

## SPECIFIC PERFORMANCE RATING

Product Water Production	666 Gallons Per Day (2521 Liters Per Day)
Average System Recovery	53.2%

Average System Recovery is the percentage of the influent water to the membrane portion of the system that is available to the user as reverse osmosis treated water when operated as designed (without a pressurized storage tank).

## SYSTEM SPECIFICATIONS AND OPERATING PARAMETERS

Inlet Water Condition	Minimum	Maximum
Pressure	22 psi ( 1.5 bar)	145 psi (10 bar)
Flow	6 L/min	-
TDS	0 mg/L	1200 mg/L
Conductivity	0 µS/cm	1600 µS/cm
Temperature	35.6 °F (2 °C)	95 °F (35 °C)
Hardness	0 mg/L	100 mg/L
Iron (II)	0 mg/L	0.3 mg/L
Iron (III)	0 mg/L	0.5 mg/L
Turbidity	0 FNU	0.5 FNU

Actual system performance will vary depending on varying water temperature and pressure, TDS levels and inlet water chemistry. Operating the system in water conditions outside the minimum or maximum operating parameters may result in reduced system performance and membrane element life.

**Warning:** Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.

## RO SYSTEM & FILTRATION COMPONENTS

Prefilter	Granulated Activated Carbon Filter	919240004
Membrane	High Rejection Membrane	155007301-SP

Refer to Owner's Manual for electrical requirements, installation instructions and servicing/replace-ment component recommendations.

## **WARRANTY**

Refer to [www.bluewatergroup.com/warranty](http://www.bluewatergroup.com/warranty) for more information on Limited warranty.

### **Bluewater Group**

Engelbrektsgatan 14  
114 32 Stockholm  
Sweden

T: +46 8- 56 473 800  
[www.bluewatergroup.com](http://www.bluewatergroup.com)

### **Bluewater China**

Room 1503 City Gateway NO.398  
North Caoxi Road  
Shanghai, China

T: +86 21 6126 6210  
[cn.bluewatergroup.com](http://cn.bluewatergroup.com)

### **Bluewater USA Inc.**

7603 W 145th Terrace  
Overland Park  
Kansas 66223, USA

T: 1-844-2Bluewater  
[us.bluewatergroup.com](http://us.bluewatergroup.com)

